



NORTH DELHI MUNICIPAL CORPORATION  
(Office of the Deputy Health Officer)  
PUBLIC HEALTH DEPARTMENT  
A-1 BLOCK, KESHAV PURAM ZONE, DELHI-110035



No. DHO/KPZ/2019/ 1706

Dated : 4/2/2019

SCHOOL HEALTH CERTIFICATE

Date of Inspection	:	04.02.2019
1. Name of the School	:	Laurel High School
2. Location	:	Behind IDPL, CHBS (Near Ashiana Chowk) Pitampura, Delhi – 110034.
3. Timing of School	:	07:30 a.m. to 02:00 p.m.
4. No. of Students	:	Total = 515
6. No. of Staff Members	:	21
7. No. of Class Rooms	:	24
8. No. of Toilets	:	26

Parameters Checked from Health Point of View

1. Sufficiency of Area	:	The floor area in the classroom is sufficient.
2. Lighting	:	The classes are well lighted.
3. Ventilation	:	The classrooms are well ventilated.
4. Cleanliness	:	The classrooms are kept neat & clean.
5. Requirement of White Wash etc.	:	Building/ Classrooms do not require white wash etc.
6. Drinking Water	:	The drinking water is wholesome.
7. Latrine Arrangement	:	The latrine arrangement is sanitary & hygienic.

In view of the above submissions this Health certificate is being issued in favour of this school by the undersigned, after being fully satisfied and having NO OBJECTION FROM HEALTH POINT OF VIEW.

The Manager,  
Laurel High School  
Behind IDPL, CHBS (Near Ashiana Chowk)  
Pitampura, Delhi – 110034.

- Office Copy

  
Dy. Health Officer  
Keshav Puram Zone  
North Delhi Municipal Corporation



**DELHI JAL BOARD**  
(Govt. of N.C.T. Delhi)  
**ZONAL LABORATORY, WATER WORKS,**  
**HAIDER PUR, DELHI-110085.**


**THE TEST REPORT IS  
FOR THIS PARTICULAR  
WATER SAMPLE ONLY.**


**TEST REPORT**


Water sample collected from DJB supply point in the premises of Laurel High The School Behind IDPL CHBS Society, Pitampura, Delhi vide challan no. 272 dated 31.01.2019.

S. No.	PARAMETERS	UNITS	S1
1.	Date of collection	--	04.02.2019
2.	Date of Analysis	--	07.02.2019
3.	Colour	Hazen	Clear
4.	Odour	--	No Obj.
5.	Turbidity	N.T.U	1.01
6.	p <sup>H</sup> value	--	7.5
7.	Electrical Conductivity	µmhos/cm	324.0
8.	Total Dissolved Solid	(mg/l)	210.6
<b>CHEMICAL EXAMINATION</b>			
9.	Phenolphthalein Alkalinity	(mg/l)	Nil
10.	Total Alkalinity	(mg/l)	82.0
11.	Total Hardness	(mg/l)	126.0
12.	Calcium Hardness	(mg/l)	88.0
13.	Magnesium Hardness	(mg/l)	38.0
14.	Calcium as Ca	(mg/l)	35.2
15.	Magnesium as mg	(mg/l)	9.12
16.	Ammonia (free & saline)	(mg/l)	Nil
17.	Nitrite -Nitrogen (N)	(mg/l)	Nil
18.	Nitrate (NO <sub>3</sub> )	(mg/l)	3.24
19.	Sulphate (SO <sub>4</sub> )	(mg/l)	25.85
20.	Chloride (Cl)	(mg/l)	10.0
21.	Iron (Fe)	(mg/l)	0.04
22.	Fluorides (F)	(mg/l)	0.43
23.	Cyanides (CN)	(mg/l)	Abst.
24.	Residual Chlorine	(mg/l)	1.0
<b>BACTERIOLOGICAL EXAMINATION</b>			
25.	Coliform per 100 ml at 37 <sup>0</sup> C	MPN/100 mL	0

**Remarks:** On the basis of tested parameters, water sample (S1) confirms to drinking water specification I.S.10500:2012, therefore it may be used for drinking purpose.

  
Asstt. Chemist

  
Chemist/Bacteriologist

  
A.C.W.A. (HP-I)